

Lower Mainland Pathology and Laboratory Medicine

=====

FAX LAB REPORT

=====

=====

MESSAGE

=====

This facsimile communication is intended only for the use of the addressee and may contain information that is privileged and confidential.

Any dissemination, distribution or copying of this communication by unauthorized individuals is strictly prohibited.

If you receive this communication in error, please notify us immediately at 1-877-747-2522.

Thank you.

---

Name: SAVARY SHORES IMPROVEMENT DISTRICT, STORAGE TANK 1  
Site Address: STREET ADDRESS 2 (FORMERLY REG2)  
System Type: REG1 (STREET1) Agency ID:  
EHO: PHSA ID: DGLR83ZMH910  
Location: E

===== CLIENT COPY FOR: VAN. COASTAL HEALTH POWELL RIV =====

ACC#: T2394776 COLL: 29/Aug/2022 08:36 REC: 30/Aug/2022 08:30  
FINAL CLIENT OR ORD. PHYS: C00181 VAN. COASTAL HEALTH POWELL RIVER, X

	RESULT	REF. RANGE	UNITS	RESULTED
Water Bacteriology Testing				
Sample Type	Drinking water			30/Aug/2022
Method Work Up				30/Aug/2022
	Membrane Filtration			
EHO	JACK DAVIDSON			30/Aug/2022
System Type (Facility Type)	WS2			30/Aug/2022
Site Source	Well			30/Aug/2022
Boil Advisory	NO			30/Aug/2022
Total Coliform	Estimated Count		Count/100mL	31/Aug/2022
	120			
Escherichia coli	High colony density on membrane prevented accurate coliform cou			
	Estimated Count		Count/100mL	31/Aug/2022
	4			
	High colony density on membrane prevented accurate coliform cou			

{D} Testing performed or reported by BC Centre for Disease Control Laboratory

LEGEND:

H/L Abnormal Value  
HH/LL Critical Value  
\*/\*\* General Laboratory - Abnormal Text Result  
\* Microbiology Susceptibility Grid - indicates comment printed below grid

Results performed or reported by the British Columbia Public Health Microbiology & Reference Laboratory, Provincial Toxicology Centre, and/or Tumour Marker Laboratory of the PHSA unless otherwise indicated. For inquiries call 1-877-PHSA LAB (1-877-747-2522) or fax 604-707-2601

This report is intended only for the use of the addressee. If this report is received in error, please immediately notify PHSA laboratories at 1-877-747-2522.

PRINTED: 31/Aug/2022 10:27

END OF REPORT

PAGE 1 OF 1

NUMBER OF QUALIFYING REPORTS: 1

CLIENT REPORT COMPLETED