

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/23/2019
Date: October 28, 2019 at 5:09 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Wellhead #1
Date Collected: 10/23/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYH Lab: BCCDC
Sample ID: TCLE-BG4R2Q Lab Sample ID: B9WD003405

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/23/2019
Date: October 28, 2019 at 5:09 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, NEW Wellhead #2
Date Collected: 10/23/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: TCLE-8VERCB Lab: BCCDC
Sample ID: TCLE-BG4R2K Lab Sample ID: B9WW060687

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/23/2019
Date: October 28, 2019 at 5:09 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: , Storage tank #1
Date Collected: 10/23/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-83ZMH9 Lab: BCCDC
Sample ID: TCLE-BG4R2N Lab Sample ID: B9WW060689

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/23/2019
Date: October 28, 2019 at 5:09 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage Tank #2
Date Collected: 10/23/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYM Lab: BCCDC
Sample ID: TCLE-BCKUGE Lab Sample ID: B9WW060729

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/23/2019
Date: October 28, 2019 at 5:09 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #1
Date Collected: 10/23/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYL Lab: BCCDC
Sample ID: TCLE-BG4R2M Lab Sample ID: B9WW060686

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/23/2019
Date: October 28, 2019 at 5:09 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #2
Date Collected: 10/23/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-7TWTFM Lab: BCCDC
Sample ID: TCLE-BGCUPK Lab Sample ID: B9WW060708

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/23/2019
Date: October 28, 2019 at 5:09 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #3
Date Collected: 10/23/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFB2F Lab: BCCDC
Sample ID: TCLE-BG4R2H Lab Sample ID: B9WW060727

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/23/2019
Date: October 28, 2019 at 5:09 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #4
Date Collected: 10/23/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: BFOH-68SPPJ Lab: BCCDC
Sample ID: TCLE-BG4R2L Lab Sample ID: B9WW060753

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen