

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2025 9:32:00 AM
Date: August 23, 2025 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Wellhead #1
Date Collected: 08/20/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYH Lab: BCCDC
Sample ID: AWEF-DHARSU Lab Sample ID: T4663115

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2025 9:37:00 AM
Date: August 23, 2025 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, NEW Wellhead #2
Date Collected: 08/20/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: TCLE-8VERCB Lab: BCCDC
Sample ID: AWEF-DHARSP Lab Sample ID: T4663110

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2025 10:12:00 AM
Date: August 23, 2025 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage tank #1
Date Collected: 08/20/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-83ZMH9 Lab: BCCDC
Sample ID: AWEF-DHARSS Lab Sample ID: T4663114

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2025 10:17:00 AM
Date: August 23, 2025 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage Tank #2
Date Collected: 08/20/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYM Lab: BCCDC
Sample ID: AWEF-DHARST Lab Sample ID: T4663116

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2025 9:57:00 AM
Date: August 23, 2025 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #1
Date Collected: 08/20/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYL Lab: BCCDC
Sample ID: AWEF-DHARSR Lab Sample ID: T4663113

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2025 9:47:00 AM
Date: August 23, 2025 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #2
Date Collected: 08/20/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-7TWTFM Lab: BCCDC
Sample ID: AWEF-DHARSN Lab Sample ID: T4663112

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2025 9:22:00 AM
Date: August 23, 2025 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #3
Date Collected: 08/20/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFB2F Lab: BCCDC
Sample ID: AWEF-DHARSM Lab Sample ID: T4663109

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2025 9:12:00 AM
Date: August 23, 2025 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #4
Date Collected: 08/20/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: BFOH-68SPPJ Lab: BCCDC
Sample ID: AWEP-DHARSQ Lab Sample ID: T4663111

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310