

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 5/23/2023 8:11:00 AM  
**Date:** May 26, 2023 at 2:02 AM  
**To:** administrator@savaryshoreswater.ca, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Wellhead #1  
Date Collected: 05/23/2023

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYH Lab: BCCDC  
Sample ID: AWEF-CQ7SN7 Lab Sample ID: F2585754

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 5/23/2023 8:30:00 AM  
**Date:** May 26, 2023 at 2:02 AM  
**To:** administrator@savaryshoreswater.ca, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, NEW Wellhead #2  
Date Collected: 05/23/2023

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: TCLE-8VERCB Lab: BCCDC  
Sample ID: AWEP-CQ7SN2 Lab Sample ID: F2585747

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 5/23/2023 8:54:00 AM  
**Date:** May 26, 2023 at 2:02 AM  
**To:** administrator@savaryshoreswater.ca, emerdubois@gmail.com, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: , Storage tank #1  
Date Collected: 05/23/2023

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: DGLR-83ZMH9 Lab: BCCDC  
Sample ID: AWEF-CQ7SN5 Lab Sample ID: F2585753

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 5/23/2023 8:56:00 AM  
**Date:** May 26, 2023 at 2:02 AM  
**To:** administrator@savaryshoreswater.ca, emerdubois@gmail.com, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Storage Tank #2  
Date Collected: 05/23/2023

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYM Lab: BCCDC  
Sample ID: AWEF-CQ7SN6 Lab Sample ID: F2585752

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 5/23/2023 8:38:00 AM  
**Date:** May 26, 2023 at 2:02 AM  
**To:** administrator@savaryshoreswater.ca, emerdubois@gmail.com, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Sample Station #1  
Date Collected: 05/23/2023

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYL Lab: BCCDC  
Sample ID: AWEF-CQ7SN4 Lab Sample ID: F2585751

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 5/23/2023 9:12:00 AM  
**Date:** May 26, 2023 at 2:02 AM  
**To:** administrator@savaryshoreswater.ca, emerdubois@gmail.com, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Sample Station #2  
Date Collected: 05/23/2023

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: DGLR-7TWTFM Lab: BCCDC  
Sample ID: AWEF-CQ7SMZ Lab Sample ID: F2585746

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 5/23/2023 9:26:00 AM  
**Date:** May 26, 2023 at 2:02 AM  
**To:** administrator@savaryshoreswater.ca, emerdubois@gmail.com, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Sample Station #3  
Date Collected: 05/23/2023

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFB2F Lab: BCCDC  
Sample ID: AWEP-CQ7SMY Lab Sample ID: F2585745

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 5/23/2023 9:40:00 AM  
**Date:** May 26, 2023 at 2:02 AM  
**To:** administrator@savaryshoreswater.ca, emerdubois@gmail.com, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Sample Station #4  
Date Collected: 05/23/2023

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: BFOH-68SPPJ Lab: BCCDC  
Sample ID: AWEP-CQ7SN3 Lab Sample ID: F2585750

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310