

From: HS Agent HAgent@healthspace.ca
Subject: Drinking Water Report for Savary Shores Improvement District - 11/20/2023 8:44:00 AM
Date: November 23, 2023 at 2:00 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Wellhead #1
Date Collected: 11/20/2023

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYH Lab: BCCDC
Sample ID: AWEP-CUZQRN Lab Sample ID: H3057204

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.ca
Subject: Drinking Water Report for Savary Shores Improvement District - 11/20/2023 8:47:00 AM
Date: November 23, 2023 at 2:00 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, NEW Wellhead #2
Date Collected: 11/20/2023

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: TCLE-8VERCB Lab: BCCDC
Sample ID: AWEP-CUZQRH Lab Sample ID: H3057200

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.ca
Subject: Drinking Water Report for Savary Shores Improvement District - 11/20/2023 9:10:00 AM
Date: November 23, 2023 at 2:00 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage tank #1
Date Collected: 11/20/2023

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-83ZMH9 Lab: BCCDC
Sample ID: AWEP-CUZQRL Lab Sample ID: H3057206

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.ca
Subject: Drinking Water Report for Savary Shores Improvement District - 11/20/2023 9:14:00 AM
Date: November 23, 2023 at 2:00 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage Tank #2
Date Collected: 11/20/2023

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYM Lab: BCCDC
Sample ID: AWEP-CUZQRM Lab Sample ID: H3057207

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.ca
Subject: Drinking Water Report for Savary Shores Improvement District - 11/20/2023 8:59:00 AM
Date: November 23, 2023 at 2:00 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #1
Date Collected: 11/20/2023

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYL Lab: BCCDC
Sample ID: AWEP-CUZQRK Lab Sample ID: H3057210

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.ca
Subject: Drinking Water Report for Savary Shores Improvement District - 11/20/2023 9:23:00 AM
Date: November 23, 2023 at 2:00 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #2
Date Collected: 11/20/2023

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-7TWTFM Lab: BCCDC
Sample ID: AWEP-CUZQRG Lab Sample ID: H3057203

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.ca
Subject: Drinking Water Report for Savary Shores Improvement District - 11/20/2023 9:31:00 AM
Date: November 23, 2023 at 2:00 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #3
Date Collected: 11/20/2023

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFB2F Lab: BCCDC
Sample ID: AWEP-CUZQRF Lab Sample ID: H3057196

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.ca
Subject: Drinking Water Report for Savary Shores Improvement District - 11/20/2023 9:43:00 AM
Date: November 23, 2023 at 2:00 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #4
Date Collected: 11/20/2023

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: BFOH-68SPPJ Lab: BCCDC
Sample ID: AWEP-CUZQRJ Lab Sample ID: H3057202

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310