

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/1/2025 9:13:00 AM
Date: October 4, 2025 at 2:12 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Wellhead #1
Date Collected: 10/01/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYH Lab: BCCDC
Sample ID: AWEF-DKCR3U Lab Sample ID: F4567772

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/1/2025 9:18:00 AM
Date: October 4, 2025 at 2:12 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, NEW Wellhead #2
Date Collected: 10/01/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: TCLE-8VERCB Lab: BCCDC
Sample ID: AWEF-DKCR3P Lab Sample ID: F4567759

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/1/2025 9:41:00 AM
Date: October 4, 2025 at 2:12 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage tank #1
Date Collected: 10/01/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-83ZMH9 Lab: BCCDC
Sample ID: AWEF-DKCR3S Lab Sample ID: F4567769

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:
Total Coliform per 100 mL: 24
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/1/2025 9:35:00 AM
Date: October 4, 2025 at 2:12 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage Tank #2
Date Collected: 10/01/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYM Lab: BCCDC
Sample ID: AWEF-DKCR3T Lab Sample ID: F4567771

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:
Total Coliform per 100 mL: 81
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/1/2025 9:48:00 AM
Date: October 4, 2025 at 2:12 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #1
Date Collected: 10/01/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYL Lab: BCCDC
Sample ID: AWEF-DKCR3R Lab Sample ID: F4567767

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:
Total Coliform per 100 mL: 144.5
E. Coli per 100 mL: 1.0

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/1/2025 9:27:00 AM
Date: October 4, 2025 at 2:12 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #2
Date Collected: 10/01/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-7TWTFM Lab: BCCDC
Sample ID: AWEF-DKCR3N Lab Sample ID: F4567757

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:
Total Coliform per 100 mL: 200.5
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/1/2025 8:42:00 AM
Date: October 4, 2025 at 2:12 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #3
Date Collected: 10/01/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFB2F Lab: BCCDC
Sample ID: AWEF-DKCR3M Lab Sample ID: F4567758

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 10/1/2025 9:02:00 AM
Date: October 4, 2025 at 2:12 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #4
Date Collected: 10/01/2025

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: BFOH-68SPPJ Lab: BCCDC
Sample ID: AWEF-DKCR3Q Lab Sample ID: F4567768

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310