

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2019
Date: August 23, 2019 at 5:08 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Wellhead #1
Date Collected: 08/20/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYH Lab: BCCDC
Sample ID: TCLE-BDGSAQ Lab Sample ID: B9WW046632

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2019
Date: August 23, 2019 at 5:08 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, NEW Wellhead #2
Date Collected: 08/20/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: TCLE-8VERCB Lab: BCCDC
Sample ID: TCLE-BDGS AJ Lab Sample ID: B9WW046661

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2019
Date: August 23, 2019 at 5:08 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: , Storage tank #1
Date Collected: 08/20/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-83ZMH9 Lab: BCCDC
Sample ID: TCLE-BDGSAM Lab Sample ID: B9WW046659

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/27/2019
Date: August 30, 2019 at 5:08 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage Tank #2
Date Collected: 08/27/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYM Lab: BCCDC
Sample ID: TCLE-BEJVT8 Lab Sample ID: B9WW048324

WATER TEST RESULTS:
Total Coliform per 100 mL: 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2019
Date: August 23, 2019 at 5:08 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #1
Date Collected: 08/20/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYL Lab: BCCDC
Sample ID: TCLE-BDGSAL Lab Sample ID: B9WW046658

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2019
Date: August 23, 2019 at 5:08 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #2
Date Collected: 08/20/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-7TWTFM Lab: BCCDC
Sample ID: TCLE-BDGS AH Lab Sample ID: B9WW046630

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/27/2019
Date: August 30, 2019 at 5:08 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #3
Date Collected: 08/27/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFB2F Lab: BCCDC
Sample ID: TCLE-BEJVRZ Lab Sample ID: B9WW048360

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 8/20/2019
Date: August 23, 2019 at 5:08 AM
To: administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #4
Date Collected: 08/20/2019

Operator: Courtney Robertson
(Blank)
(Blank), (Blank) (Blank)

Site ID: BFOH-68SPPJ Lab: BCCDC
Sample ID: TCLE-BDGS AK Lab Sample ID: B9WW046669

WATER TEST RESULTS:
Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Michael Nguyen