

Analytical Report

Bill To: Aaron Service 4703 Marine Avenue Powell River, BC, Canada V8A 2L2	Project ID: Project Name: Savary Shores Imp. Project Location: 2785 Vancouver Blvd., Savary Island	Lot ID: 1872832
Attn: Coranne Anderson	LSD:	Control Number:
Sampled By: Janine Reimer	P.O.: 437379	Date Received: Jan 29, 2026
Company:	Proj. Acct. code:	Date Reported: Jan 30, 2026
		Report Number: 3233316
		Report Type: Final Report

Reference Number	1872832-1
Sample Date	January 28, 2026
Sample Time	09:02
Sample Location	
Sample Description	2785 Vancouver Blvd. / Well # 1 / 7.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal DL	Guideline Limit	Guideline Comments
Routine Water						
Nitrate - N	Dissolved	mg/L	3.98	0.01	10	Below MAC