



HEALTH PROTECTION

PERMIT TO OPERATE

A Water Supply System

Purveyor: Savary Shores Improvement District

Facility Name: Savary Shores Improvement District

Conditions of Permit

- > **Bacteriological Sampling Frequency:** Submit a minimum of 6 distribution system samples and 1 raw source water samples per month.
- > **Chemical Analysis:** Complete a full-spectrum chemical analysis at a minimum frequency of once per year. Last completed: 2025. Next due: 2026.
- > **Nitrate Monitoring:** Complete biannual nitrate analysis.
- > **Annual Report to Water Users:** Prepare and publicly distribute the annual report within 6 months of the end of the calendar year. Date due: June 2026.
- > **Emergency Response Planning:** Review and update the Emergency Response and Contingency Plan on an annual basis. Last updated: 2025. Next due: June 2026.
- > **Long-term Planning:** Provide a long-term plan outlining either the installation of water treatment or the implementation of a permanent water quality advisory, as identified in the inspection and evaluation reports dated May 30, 2025, and March 24, 2026.

September 1, 1999

Effective Date

March 24, 2026

Revised Date

Drinking Water Officer

This permit must be displayed